

1 | 2 | 3 | 4 | 5 | 6

WEAR

BLACK RI6s

6 Months of the Year

Live Line Safety provides dielectric testing with quick turnaround time for Rubber Insulating Gloves (RI6). These gloves must be tested before first issue and every 6 months thereafter. We ensure our tests meet or exceed ASTM F496 safety standards.

Our recommended RI6 Rotation ProgramSM provides a practical approach and a cost effective service to maintain compliance and continuity. With this process colored RI6s and all black RI6s can easily be identified and tracked.

Ensure your workers are safe and have Live Line Safety test your personal protective equipment to comply with applicable OSHA standards.

7 | 8 | 9 | 10 | 11 | 12

WEAR

COLORED RI6s

for remaining 6 Months

* Before each use, visually inspect your rubber insulating gloves. Follow manufacturer's instructions regarding inspection, storage and use.